

No DX1300361


# Test Report

Name of sample Polymeric insulated 12.7/22(24)kV  
distribution network cables

Specifications XLPE 12.7/22kV 3×185mm<sup>2</sup>

Inspected unit Guangdong Nanyang Cable Group Holding Co.,Ltd.

Test purpose Type Test




Guangdong Testing Institute Of Product Quality Supervision  
(GQI)

# Guangdong Testing Institute of Product Quality Supervision

## TEST REPORT

No DX1300361

P.1/7

Name of sample	Polymeric insulated 12.7/22(24) kV distribution network cables	Type	XLPE 12.7/22kV 3×185mm <sup>2</sup>
		Trade mark	NAN
Inspected unit	Guangdong Nanyang Cable Group Holding Co.,Ltd.	Test purpose	Type Test
Produced by	Guangdong Nanyang Cable Group Holding Co.,Ltd.	Class of sample	—
Place of sampling	—	Date of sampling (receiving)	2013.02.05
Quantity of sampling	30 m	Person of sampling (sending)	LIN Liantao
Basic quantity of sampling	—	No. of sample tested or produced date	—
Based on	AS/NZS 4026:2008 Electric cables— For underground residential distribution systems	Tested items	59 items
Remarks	<p>59 items were checked according to AS/NZS 4026:2008, the test results met the technical requirements based on .</p> <div style="text-align: center;">  </div>		
Notes	Bill of testing plan: YDD13/0642.		

Approved by: 

Checked by: 

Tested by: 