

Independent, accredited testing station  $\cdot$  Member laboratory of STL and LOVAG

				<u></u>
NO. 3593.2101273.0962				
Guangdong Nanyang Cable Group Holding Co. Ltd. (NANC) Industry Zone 515041 Shantou CHINA	No.1 Zhujin Er St. Z	hujin		CLIENT
Guangdong Nanyang Cable Group Holding Co. Ltd. (NANC)	No.1 Zhujin Er St. Z	hujin		MANUFACTURER
Power cable with extruded insulation				TEST OBJECT
20 kV XLPE insulated cable, PVC sheathed, with aluminium conductor 400 mm², copper wire screen 35 mm²				ТҮРЕ
Cable sample, Order confirmation 2101273 (marking on sheath)				SERIAL NO.
Rated voltage	U <sub>n</sub> /U	12/20	kV	RATED
Max. operation voltage	U <sub>m</sub>	24	kV	CHARACTERISTICS GIVEN BY THE CLIENT
IEC 60502-2: 2005-03				NORMATIVE DOCUMENT
Electrical and non-electrical type tests on cable				RANGE OF TESTS PERFORMED
October 2010 to January 2011				DATE OF TEST
The tests have been PASSED.				TEST RESULT

H. ZINNBAUER

Head of Centre of Competence High-Power/High-Voltage

Berlin, 11 February 2011

G. BROSE

Test engineer in charge



