


No DX1302661



Test Report

Name of sample PVC insulated, PVC sheathed cables

Specifications V-90 450/750V 1 mm² × IC

Inspected unit Nanyang Cable (Tianjin) Co., Ltd.

Test purpose Commission Test




**Guangdong Testing Institute of Product Quality Supervision
(GQI)**


Guangdong Testing Institute of Product Quality Supervision

Test Report

No DX1302661

P.1/13

Name of sample	PVC insulated, PVC sheathed cables	Type	V-90 450/750V 1mm ² × 1C
		Trade mark	NAN
Inspected unit	Nanyang Cable (Tianjin) Co., Ltd.	Test purpose	Commission Test
Produced by	Nanyang Cable (Tianjin) Co., Ltd.	Class of sample	—
Place of sampling	—	Date of sampling (receiving)	2013.09.09
Quantity of sampling	50m	Person of sampling (sending)	LI Yewu
Basic quantity of sampling	—	No. of sample tested or produced date	—
Based on	AS/NZS 5000.2: 2006 Electric cables-Polymeric insulated Part 2: For working voltages up to and including 450/750V	Tested items	See the report
Remarks	The samples tested met the requirements of the AS/NZS 5000.2: 2006 . 		
Notes	1. Bill of testing plan: YDD13/003052. 2. Specification applied: (1)AS/NZS 5000.2:2006, (2)AS/NZS 3808:2000+A1:2002+A2:2004, (3)AS/NZS 1660.1:1998, (4)AS/NZS 1660.2.1:1998+A1:2001, (5)AS/NZS 1660.2.3:1998+A1:2000, (6) AS/NZS 1660.3:1998+A1:2001, (7)AS/NZS 1660.5.6:2005, (8)AS/NZS 1125:2001+A1:2004 3.This report must be used with the reports of reference No. DX1302659 and No. DX1302660.		

Approved by:  Checked by: 余翔 Tested by: 