



No DX1302674

# Test Report

Name of sample PVC Building Wire

Specifications Cu/V-90 0.6/1KV 1×630

Inspected unit Nanyang Cable (Tianjin) Co., Ltd.

Test purpose Commission Test




**Guangdong Testing Institute Of Product Quality Supervision  
(GQI)**

# Guangdong Testing Institute of Product Quality Supervision

## Test Report

No DX1302674


P.1/9

Name of sample	PVC Building Wire	Type	Cu/V-90 0.6/1KV 1×630
		Trade mark	NAN
Inspected unit	Nanyang Cable (Tianjin) Co., Ltd.	Test purpose	Commission Test
Produced by	Nanyang Cable (Tianjin) Co., Ltd.	Class of sample	—
Place of sampling	—	Date of <del>sampling</del> (receiving)	2013.09.06
Quantity of sampling	30m	Person of <del>sampling</del> (sending)	LI Yuewu
Basic quantity of sampling	—	<del>No. of sample tested</del> or produced date	—
Based on	AS/NZS 5000.1: 2005+A1:2006 Electric cables-Polymeric insulated Part 1: For working voltages up to and including 0.6/1(1.2)kV	Tested items	See the report
Remarks	<p>The sample tested met the requirements of the AS/NZS 5000.1: 2005+A1:2006 .</p> 		
Notes	<p>1.Bill of testing plan: YDD13/003056. 2.Specification applied: (1)AS/NZS 5000.1:2005+A1:2006, (2)AS/NZS 3808:2000+A1:2002+A2:2004, (3)AS/NZS 1660.1:1998, (4)AS/NZS 1660.2.1:1998+A1:2001, (5)AS/NZS 1660.2.3:1998+A1:2000, (6) AS/NZS 1660.3:1998+A1:2001, (7)AS/NZS 1660.5.6:2005, (8)AS/NZS 1125:2001+A1:2004 3.This report must be used with the reports of reference No. DX1302673.</p>		

Approved by:



Checked by :



Tested by :

